

Jan 2015



Room Temperature Logs

Reference Ranges

Room Temp: 19° - 23° C (66° - 73° F)  
Humidity: 35% - 60%

Day	Room A (Anteroom)			Room P (Positive Pressure)			Room C (Checking)			Room N (Negative Pressure)			Room S (Storage)			
	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity
1																
2																
3																
4	66.9	67	71.6	80%	71.3	63	73.4	45%	71.2	72	74.9	67%	71.3	70	74.3	60%
5	69.8	67	72.3	75%	70.5	63	73.6	45%	71.2	72	74.9	58%	71.6	70	74.3	58%
6	69.7	67	73.4	76%	73.1	63	73.5	44%	74.3	72	75.2	59%	70.3	70	73.3	59%
7	67.9	65	72.0	43	71.4	63	73.6	29	75.3	71	74.9	43	72.5	70	74.3	42
8	67.5	67	71.2	35	70.7	69	73.3	25%	72.4	69	73.8	31%	71.5	70	74.5	31%
9																
10																
11	70	67	72.7	70%	72.0	69	73.3	44%	73.6	69	73.8	68%	72.4	70	74.5	61%
12	69.1	67	72.7	80	71.8	69	73.8	45	73.9	69	74.2	69	71.8	69	74.5	55
13	70.4	67	72.5	82	72.0	70	73.4	46	73.4	72	74.3	65	73.4	70	74.0	58
14	69.5	67	72.0	74	70.4	70	73.4	47	73.3	72	74.7	61	72.7	70	74.2	60
15	70.6	67	71	71	72.0	70	73.1	41	72.5	71	73.9	51	72.5	70	74.2	63
16																
17																
18	68.8	67	71.6	61%	70.9	69	72.9	35%	72.5	70	73.4	56%	71.3	70	74.3	51%
19	71.6	67	72.0	71%	71.4	69	73.3	27%	73.3	70	73.4	42%	72.2	70	74.3	47%
20	69.9	67	72.2	49%	71.5	69	73.6	36%	72.5	70	73.6	53%	73.4	70	74.3	50%
21	70.4	67	72.2	70%	72	69	73.6	44%	73.3	70	74.2	60%	73.4	70	74.3	54%
22	70.2	67	72.2	75%	72.6	71	72.2	46%	74.3	74	74.3	61%	71.6	70	74.3	54%
23																
24																
25	68.4	67	72.2	49%	72.2	69	73.4	26%	72.4	70	74.7	44%	71.1	70	74.3	39%
26	70.6	67	72.2	52%	71.6	69	73.4	37%	72.5	70	74.1	51%	73.1	70	74.3	50%
27	69.8	67	72.2	59%	71.1	68	73.4	36%	72.7	70	74.7	50%	71.3	70	74.3	51%
28	68.4	67	72.2	58%	70.7	69	73.4	25%	72.6	70	74.7	39%	72.4	70	74.3	39%
29	71.3	67	72.2	41%	70.7	69	73.4	24%	72.0	70	74.7	44%	72.4	70	74.3	42%
30																
31																

Bottle  
92.4kg  
0.847



oncology plus

# Fridge and Freezer Temperature Logs

Day	36°F 46°F		36°F		14°F		91°F		99°F	
	°F	°F min	°F min	°F max	°F min	°F max	°F	°F min	°F min	°F max
1										
2										
3										
4	33.6	30.4	36.7	33.8	-11	-12	47	96	96	96
5	30.5	29.4	37.0	33.8	-10	-12	96	93	93	93
6	28.4	27.2	37.0	33.8	-10	-12	94	94	94	94
7	30.3	28.5	31.5	33.6	-9	-12	96	95	95	95
8	34.3	29.7	40.3	34.3	-10	-11	99	94	94	94
9										
10										
11	31.8	29.5	42.6	33.3	-9	-12	98	96	96	96
12	36.3	29.5	39.9	33.3	-9	-12	96	96	96	96
13	34.2	29.5	31.7	34.5	-8	-9	99	94	94	94
14	35.8	29.5	36.3	31.6	-9	-9	98	93	93	93
15	31.5	29.4	39.8	33.6	-9	-10	98	94	94	94
16										
17										
18	36	29.5	36.1	34.2	-9	-10	95	94	94	94
19	37.5	29.3	45.1	34.2	-9	-10	99	93	93	93
20	35.2	29.3	36.1	34.2	-9	-10	97	93	93	93
21	32.7	29.3	42.6	34.2	-10	-10	95	93	93	93
22	35.1	29.3	43	34	-9	-10	97	93	93	93
23										
24										
25	32.2	29.5	34	40.8	-10	-11	97	92	92	92
26	35.8	29.5	40.4	34	-9	-11	99	93	93	93
27	33.8	29.5	29.2	34	-9	-11	99	93	93	93
28	34.0	29.5	40.8	34	-10	-11	97	93	93	93
29	37.0	29.7	45.3	33.8	-9	-11	97	93	93	93
30										
31										

YEAR 2015

Month Jan