

Feb 2015

oncology plus

Room Temperature Logs

Reference Ranges

Room Temp: 19° - 23° C (66° - 73° F)
Humidity: 35% - 60%

Day	Room A (Anteroom)				Room P (Positive Pressure)				Room C (Checking)				Room N (Negative Pressure)				Room S (Storage)				
	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	
1	68	66	72.2	43%	70	67	73.6	28%	72.4	69	74.7	40%	73.3	70	74.5	39%	70.2	59	77	58%	
2	69.5	66	72.2	69%	71.8	67	73.6	46%	73.3	69	74.7	60%	73.1	70	74.5	56%	74.2	59	77	61	
3	70.9	66	72.2	40%	71.3	67	73.6	27%	72.4	69	74.7	40%	73.1	69	74.5	39%	69.5	59	77	43%	
4	70.2	65	72.2	60%	71.7	67	73.6	45%	73.4	69	74.7	53%	71.8	69	74.5	52%	71.0	59	77	54%	
5	69.8	65	72.2	69%	72.2	67	73.6	46%	73.1	69	74.7	58%	71.9	69	74.5	52%	73.4	59	77	62%	
6																					
7																					
8	69.3	67	71.8	55%	70.6	68	73.1	30%	73.1	70	73.4	51%	71.8	70	74.9	49%	72.2	67	73.8	52%	
9	70.6	66	71.8	71%	72.5	68	73.3	46%	73.1	70	74.0	60%	72.4	70	74.9	61%	72.9	67	75.8	63%	
10	70.0	67	71.8	61%	71.6	69	73.3	36%	72.9	71	73.8	55%	72.5	70	74.2	50%	72.2	69	73.3	56%	
11	70.9	67	70.9	48%	71.6	68	73.3	29%	72.7	70	74.0	47%	72.7	70	74.2	48%	71.1	67	74.5	50%	
12	68.8	67	71.6	45%	72.2	68	73.4	29%	72.7	70	74.0	50%	72.0	70	73.4	49%	71.5	67	74.9	57%	
13																					
14																					
15	68.8	65	72.0	40%	72.9	68	73.3	27%	74.2	69	74.2	44%	72.7	69	74.3	41%	72.2	63	77.2	40%	
16	68.8	65	72.0	48%	72.5	68	74.0	34%	74.7	69	76.3	49%	72.0	69	74.3	52%	72.4	63	79.7	44%	
17	70.4	67	71.3	69%	72.0	70	73.4	44%	74.0	73	75.1	59%	72.2	70	74.2	56%	72.8	74	77.6	52%	
18	69.9	67	71.6	35%	72.5	69	73.4	26%	73.8	72	75.1	57%	71.6	70	74.5	35%	71.6	74	77.4	35%	
19	71.5	67	72.2	25%	72.1	69	73.8	26%	72.2	70	75.1	24%	72.5	70	74.5	25%	74.2	72	78.1	25%	
20																					
21																					
22	68.9	67	72.9	56%	72.2	68	73.6	35%	75.4	69	75.6	54%	72.2	68	73.6	48%	76.7	70	77.8	49%	
23	70.4	63	72.2	28%	72.5	68	74.2	48%	74.7	69	76.1	60%	72.4	69	74.7	62%	74.5	70	77.8	55%	
24	72.6	67	71.5	79%	71.8	70	73.6	40%	74.2	71	75.1	64%	73.1	69	74.7	63%	75.6	73	77.4	57%	
25	72.4	68	71.6	74%	72.5	70	73.8	45%	74	73	75.6	68%	72.8	70	74.5	68%	77	73	77.4	55%	
26	69.1	67	71.6	65%	70.9	69	73.1	36%	74.5	73	75.8	57%	70.6	70	73.6	53%	74.5	73	77.8	49%	
27																					
28																					
29																					
30																					
31																					