

PARTIAL VIAL CHECK

Month/Year March 2015

(INCHES W.C.)

ANTEROOM	NON-CHEMO ROOM	CHEMO ROOM	BSC#1	BSC#2
1	.09	.11	-.06	
2	.09	.11	-.06	
3	.09	.11	-.06	
4	.09	.11	-.06	
5	.10	.13	-.07	
6	/	/	/	
7	/	/	/	
8	.10	.12	-.06	
9	.10	.12	-.06	
10	.09	.11	-.06	
11	.09	.11	-.06	
12	.09	.11	-.06	
13	/	/	/	
14	/	/	/	
15	.10	.12	-.07	
16	.10	.12	-.07	
17	.10	.12	-.08	
18	.12	.11	-.05	
19	.12	.10	-.05	
20	/	/	/	
21	/	/	/	
22	.10	.12	-.07	
23	.09	.12	.08	
24	.10	.13	-.05	
25	.09	.11	-.04	
26	.09	.13	-.04	
27	/	/	/	
28	/	/	/	
29	.09	.12	-.05	
30	.09	.11	-.05	
31	.09	.11	-.05	

Reference Range	
Non-Chemo	> 0.02
Chemo	< -0.01
Anteroom	> 0.02