

March 2015

oncology plus

Room Temperature Logs

Reference Ranges

Room Temp: 19° - 23° C (66° - 73° F)

Humidity: 35% - 60%

Day	Room A (Anteroom)			Room P (Positive Pressure)			Room C (Checking)			Room N (Negative Pressure)			Room S (Storage)								
	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity					
1	70.2	67	72.0	73%	73.3	70	73.6	47%	74.5	71	75.2	59%	72.4	70	74.5	62%	75.1	72	77.9	55%	
2	69.1	67	72	60%	72	70	74.2	35%	71.7	71	75.8	57%	72.2	70	74.5	52%	74.1	72	77.9	54%	
3	68.9	67	72.4	61%	72.2	70	74.7	34%	75.1	72	75.8	59%	72.2	70	74.5	48%	74.9	73	77.4	53%	
4	69.3	67	72.5	61%	72.2	70	74.5	35%	74.5	72	75.8	59%	72.2	70	74.5	52%	74.9	73	77.4	53%	
5	69.8	68	72.2	59%	72.2	69	74.2	36%	75.2	72	75.8	58%	72.5	70	74.5	52%	74.9	73	77.4	53%	
6																					
7																					
8	68.4	66	72.5	50%	71.5	70	74.2	30%	74.2	72	75.8	50%	71.6	70	74.7	45%	74.9	72	77.2	47%	
9	71.5	66	72.5		71.8	70	74.2	33%	74.4	72	75.8	52%	71.9	71	74.5	48%	75.0	72	77.4	48%	
10	72	66	72.5	69%	72.2	70	74.5	34%	75.1	71	76	55%	72.2	70	74.7	48%	75.2	72	78.1	51%	
11	70	67	72.4	60%	72.2	70	74.2	40%	75.1	72	75.8	60%	72.2	70	73.4	59%	76.5	72	76.7	56%	
12	69.8	66	72.5	59%	72.4	69	74.2	36%	75.2	72	76	56%	72.7	70	75.1	52%	76.3	72	76.5	54%	
13																					
14																					
15	71.5	66	72.4	60%	70.9	69	73.8	44%	74.9	72	75.8	59%	71.8	70	74.7	52%	74.7	71	77.0	54%	
16	69.1	66	72.4	59%	72.9	69	74.0	35%	75.2	72	75.8	55%	72.7	70	74.7	48%	74.1	71	77	49%	
17	69.5	66	72.5	62%	71.3	70	74.2	32%	74.9	72	76.1	52%	71.8	70	74.5	47	77.0	69	77.9	44%	
18	70.7	67	72.0	56%	71.8	70	74.2	34%	74.5	72	76.1	51	73.8	70	74.5	45	75.6	69	77.9	48	
19	68.9	67	72.0	52%	71.5	70	74.2	33	75.1	72	76.1	53	73.8	70	74.7	44	74.5	69	77.9	49	
20																					
21																					
22	69.3	67	72.4	57%	70.4	69	74.2	34%	74.5	72	76.1	56%	71.3	70	74.9	51%	75.4	69	77.9	54%	
23	68.9	67	72.4	57%	72.2	69	74.2	35	74.5	72	76.1	57	72.0	70	74.9	50	75.6	69	77.9	49%	
24	70.9	67	72.5	60%	72.2	69	74.2	36	74.2	72	76.1	52	75.2	69	77.9	46	74	70	74.9	49%	
25	70.8	67	72.5	61%	71.6	69	74.3	33	75.4	72	76.1	51	72.2	70	74.9	47	75.4	69	77.9	49	
26	69.7	67	72.1	57	73.1	69	74.3	36	73.1	69	74.3	56	72.2	70	74.9	52	74.3	69	78.5	54	
27																					
28																					
29	71.3	65	73.1	37%	73.6	69	74.3	25%	75.4	72	76.1	36%	72.5	70	74.9	35%	78.7	69	79.2	33%	
30	71.3	69	74.3	26	70.4	69	74.3	29%	75.6	72	76.9	39%	77.4	69	79.6	35%	72.4	70	75.2	42	
31	70.2	65	73.1	54	72.9	69	71.3	37	76.4	72	76.9	55	76.9	69	79.6	48	72.2	70	75.2	52	