

PARTIAL VIAL CHECK

Month/Year April 2015

(INCHES W.C.)

ANTEROOM	NON-CHEMO ROOM	CHEMO ROOM	BSC#1	BSC#2
1	.12	.14	-.05	
2	.11	.13	-.05	
3				
4				
5	.09	.11	-.05	
6	.09	.10	-.05	
7	.12	.14	-.04	
8	.09	.11	-.05	
9	.10	.12	-.05	
10				
11				
12	.09	.11	-.07	
13	.09	.12	-.07	
14	.12	.14	-.04	
15	.09	.11	-.05	
16	.09	.11	-.05	
17				
18				
19	.09	.10	-.05	
20	.09	.10	-.05	
21	.10	.11	-.05	
22	.10	.12	-.05	
23	.10	.12	-.05	
24				
25				
26	.09	.11	-.05	
27	.09	.11	-.05	
28	.09	.11	-.05	
29	*.10	.12	-.05	
30	.10	.12	-.05	
31				

Reference Range	
Non-Chemo	> 0.02
Chemo	< -0.01
Anteroom	> 0.02