

6

April 2015

oncology plus

Room Temperature Logs

Reference Ranges

Room Temp: 19° - 23° C (66° - 73° F)

Humidity: 35% - 60%

Day	Room A (Anteroom)			Room P (Positive Pressure)			Room C (Checking)			Room N (Negative Pressure)			Room S (Storage)			
	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity	°F	°F min	°F max	Humidity
1	68.6	65	73.1	48%	71.5	69	74.3	31	74.5	72	76.9	51	73.6	69	79.6	47
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	69.8	69	73.1	55%	72.9	69	74.3	37%	75.2	72	76.9	56%	75.6	69	79.6	50%
6	69.8	69	74.7	52	73.4	69	74.9	55	70.9	69	74.7	37	75.2	69	79.6	52
7	69.1	65	73.1	53	71.6	69	74.7	35	71.7	72	76.9	64	75.2	69	79.6	51
8	70.4	65	73.1	60	74.7	69	72.0	36	73.8	72	76.9	60	76.0	69	79.6	52
9	69.1	65	72.3	53	71.6	69	74.7	36	74.3	72	76.9	55	76.1	69	79.6	50
10	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
11	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
12	72.2	65	73.1	63%	73.4	69	74.7	38%	74.9	72	76.9	57%	75.4	69	79.6	52%
13	69.2	65	73.1	64	71.5	69	74.7	41	74.9	72	76.9	62	75.6	69	79.6	54
14	70.2	65	73.1	67	73.1	69	74.7	43	74.3	72	76.9	58	74.2	69	79.6	52
15	69.7	65	73.1	57	71.8	69	74.7	36	74.7	72	76.9	55	74.4	69	79.6	51
16	74.7	69	79.6	53	71.1	69	74.7	69	74.5	72	76.9	59	74.3	69	79.6	57
17	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
18	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
19	69.8	65	73.1	61%	71.6	69	74.7	40%	73.8	72	76.9	63%	74.3	69	79.6	58%
20	69.5	65	73.6	62%	72.5	69	75.1	40%	73.2	72	76.9	61	74.9	69	79.6	59%
21	69.5	65	73.6	63	73.1	69	75.1	32	75.1	72	76.9	53	77.6	69	79.6	45
22	69.5	65	73.6	53	71.6	69	75.1	35	74.7	72	76.9	54	77.0	69	79.6	57
23	/	/	/	/	72.0	69	75.1	30	74.7	72	76.9	57	76.5	69	79.6	44
24	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
25	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
26	70.4	65	73.6	60%	72.9	69	75.1	40%	75.1	72	76.9	62%	74.3	69	79.6	56%
27	69.9	65	73.6	58%	71.6	69	75.1	32	74.2	72	76.9	53%	73.8	69	79.6	44
28	69.1	65	73.6	54	71.7	69	75.1	34	73.4	72	76.9	53	74.9	69	79.6	51
29	69.5	65	73.6	54	71.5	69	75.1	34	74.3	72	76.9	54	75.8	69	79.6	52
30	68.0	65	73.6	57	70.9	69	75.1	29	74.3	72	76.9	49	74.9	69	79.6	46
31	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/